



FIRE DEPARTMENT

Phone: 218.326.7639
FAX: 218.326.7655
E-mail: grfire@grandrapidsmn.org
Address: 420 North Pokegama Avenue
Grand Rapids, Minnesota 55744



Underground Fuel Tank Installations/Removals Permit

- 1. Underground fuel storage tanks shall be permitted prior to installation or removal.**
- 2. Each tank installed or removed requires a separate permit.**
- 3. A site plan shall be provided by permit applicant.**
- 4. Any removal of fuel storage tanks requires testing for soil contamination. Documentation shall be provided to code official.**
- 5. Underground fuel storage tanks can be abandoned in place with prior approval of the Fire Inspector.**
- 6. All fuel storage tank removals and installation shall comply with the current Minnesota State Fire Code and applicable NFPA standards.**
- 7. Any fuel leaks that result from the removal or installation of an underground fuel storage tank shall be reported to the**

Minnesota Pollution Control Agency and the Grand Rapids Fire Department.

8. Any contamination found in the soil shall be reported to the Minnesota Pollution Control Agency and the Grand Rapids Fire Inspector.

9. The Grand Rapids Safety Department shall be notified prior to any testing prior to installation.